

# SEPTIC TANK SPECIFICATION SHEET

## GENERAL

**Tank Dimensions:** 2200W x 2578H at 3000Kg

**Inlet Invert:** 1690mm +/- 20mm

**Inlet Outlet:** 1610mm +/- 20mm

**Recommended** Standard Depth: 2350mm

**Finished Ground:** 700mm (*see note*)

**High Water Table:**

If the site has a high water table. De-watering is required

**Includes:**

- Effluent Filter
- Inlet
- Outlet
- Filter
- Riser

## VISIBLE AFTER INSTALLATION

**Maintenance Lid:**

Concrete - 700 diameter

**x2 Vent Pipes:**

110mm diameter



**NOTE:**

Finished ground level: Bare land, allow for landscaping, i.e: Topsoil.

## TANK ILLUSTRATION

